
INSPECTION SUMMARY REPORT
New York State Department of Labor Asbestos Control Bureau
CASE NUMBER : 26055122 **PROJECT SITE : 68 Church Rd**
Canajoharie, NY

VIOLATIONS ISSUED TO: Mark Lindsley dba Infinity Enterprises
43 Kelly Road
Fulton, NY 13069

Inspection Date: 07/31/2014
Violation Issued: 01/29/2015

56-8.5.E Waste Clean-Up Procedures - Waste Housekeeping

Violation Status: Issued
Created By: Louis Carrock

The regulated abatement work area, holding area, waste trailer and hardtop dumpster areas must be kept free of uncontainerized asbestos waste/debris at all times.

Inspector's Observations:

Dumpsters not kept free of uncontainerized asbestos debris. Loose uncontainerized friable asbestos observed in dumpster.

Inspection Date: 07/31/2014
Violation Issued: 01/29/2015

56-8.9.G Equipment and Waste Container Decontamination and Removal Procedure - Trailers and Dumpsters

Violation Status: Issued
Created By: Louis Carrock

Waste transport trailers and dumpsters used to transport RACM waste, shall be hard topped, lockable and lined with two (2) layers of six (6) mil fire-retardant polyethylene. Prior to transport from the work site, all waste trailers and dumpsters shall be sealed to ensure air, dust and watertight integrity, utilizing six (6) mil plastic, duct tape and expandable foam sealant as necessary. The waste transporter is responsible for cleaning/decontamination of waste trailers or dumpsters, once the waste has been properly disposed of at the appropriately licensed and permitted landfill facility. Waste haulers (truck drivers) accessing the work area to remove waste trailers/dumpsters do not require certification as asbestos handlers. Waste hauler truck operators shall be allowed within the regulated work area for loading of waste and shall remain in their vehicle with the windows up and the ventilation system off while in the work area.

Inspector's Observations:

Contractor did not use hard topped dumpsters to transport RACM as required by this Section.

INSPECTION SUMMARY REPORT
New York State Department of Labor Asbestos Control Bureau

CASE NUMBER : 26055122 **PROJECT SITE : 68 Church Rd**
Canajoharie, NY

Initial Notification Date: 07/15/2014

Asbestos Project Notification

Project Reference Number: 26055122

Type: Initial Notification

Status: Notification Received

Notification Received: 7/15/2014

Payment Status: Unpaid

Number of amendments: 0

Notification Entered By: Infinity Enterprises

Contractor Information

FEIN:300517160

Infinity Enterprises

Mailing Address

43 Kelly Road

Fulton NY 13069

Asbestos License Number: 75459

Duly Authorized Representative

Mark Lindsley, Manager

Phone Number: 315-532-3375

E-mail Address: infinityenterprises14@yahoo.com

Project Information

Project Start Date: 7/28/2014

Project End Date: 7/27/2015

Project Location County: Montgomery

Worker Compensation

Worker Compensation Policy#: 76WEGGE2517

WC Exemption Certificate#:

Number of your employees you expect to be on project: 2

Will temporary workers be used? NO

If yes, name of temporary agency:

Project Location

Building Name: Beech Nut

Room or Location:

Bridge ID#:

Address Line 1: 68 Church Rd

Address Line 2:

City Town or Village: Canajoharie

State: New York

Zip Code: 13317

INSPECTION SUMMARY REPORT
New York State Department of Labor Asbestos Control Bureau

CASE NUMBER : 26055122 **PROJECT SITE : 68 Church Rd**
Canajoharie, NY

Building Information	
Current Use: Vacant	
Prior Use: Industrial	
Approximate Year Built: 1900	
Size(sq.ft): 466864	
Is this fee exempt project?: NO	
Reason:	

Building Representative/Site Contact	
Name: Todd Clifford	
Phone Number: 513-266-6414	
E-mail Address:	
Cell Phone Number:	

Phase Details				
Phase #	Phase Start Date	Phase End Date	Phase Location	Phase Scope

Sub-Contractor Details	
Name:	Asbestos License Number:

Night/Weekend/Shift Work Details

Party for Whom Work is being Performed			
First Name:	Todd	Last Name:	Clifford
Organization:	TD Development llc		
Apt./Suite:		Address Line 1:	720 Eagleview ct
Address Line 2:		City Town or Village:	Mason
Province:		State:	OH
Zip Code:	45040	Country:	United States
Contract Dollar Amount:	\$64,000.00		

Variance Information
Individual Variance Petition Number: 14-0590

Procedures and Type of Equipment and Ventilation Systems Used
Remove friable asbestos according to variance and non friable floor tile and dispose of. Demo structure, with water, with non friable roofing intact then dispose of.

Air Monitoring Firm	
Name:	Asbestos License Number:
TES Environmental Corp	29345

Laboratory Performing Analysis	
Name:	ELAP Registration Number:
TES Environmental, inc	10890

Type of Asbestos Work			
Pipe Related:	Yes	Siding:	No
Clean up:	No	Vessel covering:	No
Caulking/mastic:	No	Spray-on insulation:	No
Roofing/flashing:	Yes	VAT:	No
Demolition:	Yes	Demolition Ref#:	
Other-specify:			

INSPECTION SUMMARY REPORT
New York State Department of Labor Asbestos Control Bureau

CASE NUMBER : 26055122 **PROJECT SITE : 68 Church Rd**
Canajoharie, NY

Waste Transporter

Name: Ciotti NYS DEC or EPA Permit Number: 7A-480 Phone Number: 315-463-4416 Apt./Suite: Address Line 1: 6533 Badgley rd Address Line 2: City Town or Village: East Syracuse Province: State: NY Zip Code: 13057 Country: United States

Landfill

Name: Ontario County Landfill Phone Number: 585-526-4420 Apt./Suite: Address Line 1: 1879 St. Rt. 5 Address Line 2: City Town or Village: Stanley Province: State: NY Zip Code: 14561 Country: United States

Type and Amount of Asbestos Containing Material
--

Friable linear feet:	0	Friable square feet:	4000
Non-friable linear feet:	0	Non-friable square feet:	466864

Fee

Total linear feet: 0.0 Total square feet: 470864.0 Total Fee: 2000.0
--

Project Fee Schedule

If the notification was submitted prior to 4/7/09, the actual project fee is one half of the amount shown on the fee schedule

Linear Feet:	Fee	Square Feet:	Fee
0 - 259 feet:	\$0	0 - 159 feet:	\$0
260 - 429 feet:	\$200	160 - 259 feet:	\$200
430 - 824 feet:	\$400	260 - 499 feet:	\$400
825 - 1649 feet:	\$1000	500 - 999 feet:	\$1000
1650 or more feet:	\$2000	1000 or more feet:	\$2000

Remarks

INSPECTION SUMMARY REPORT
New York State Department of Labor Asbestos Control Bureau

CASE NUMBER : 26055122 **PROJECT SITE : 68 Church Rd**
Canajoharie, NY

Most Recent Notification Date: 07/23/2014

Asbestos Project Notification

Project Reference Number: 26055122	Type: Amended Notification
Status: Notification Received	Notification Received: 7/15/2014
Payment Status: Paid in full	Number of amendments: 1
Notification Entered By: Infinity Enterprises	

Contractor Information

FEIN:300517160

Infinity Enterprises

Mailing Address

43 Kelly Road

Fulton NY 13069

Asbestos License Number: 75459

Duly Authorized Representative

Mark Lindsley, Manager

Phone Number: 315-532-3375

E-mail Address: infinityenterprises14@yahoo.com

Project Information

Project Start Date: 7/28/2014

Project End Date: 7/27/2015

Project Location County: Montgomery

Worker Compensation

Worker Compensation Policy#: 76WEGGE2517

WC Exemption Certificate#:

Number of your employees you expect to be on project: 2

Will temporary workers be used? NO

If yes, name of temporary agency:

Project Location

Building Name: Beech Nut

Room or Location:

Bridge ID#:

Address Line 1: 68 Church Rd

Address Line 2:

City Town or Village: Canajoharie

State: New York

Zip Code: 13317

INSPECTION SUMMARY REPORT
New York State Department of Labor Asbestos Control Bureau

CASE NUMBER : 26055122 **PROJECT SITE : 68 Church Rd**
Canajoharie, NY

Building Information	
Current Use: Vacant	
Prior Use: Industrial	
Approximate Year Built: 1900	
Size(sq.ft): 466864	
Is this fee exempt project?: NO	
Reason:	

Building Representative/Site Contact	
Name: Todd Clifford	
Phone Number: 513-266-6414	
E-mail Address:	
Cell Phone Number:	

Phase Details				
Phase #	Phase Start Date	Phase End Date	Phase Location	Phase Scope

Sub-Contractor Details	
Name:	Asbestos License Number:

Night/Weekend/Shift Work Details

Party for Whom Work is being Performed			
First Name:	Todd	Last Name:	Clifford
Organization:	TD Development llc		
Apt./Suite:		Address Line 1:	720 Eagleview ct
Address Line 2:		City Town or Village:	Mason
Province:		State:	OH
Zip Code:	45040	Country:	United States
Contract Dollar Amount:	\$64,000.00		

Variance Information
Individual Variance Petition Number: 14-0590

Procedures and Type of Equipment and Ventilation Systems Used
Remove friable asbestos according to variance and non friable floor tile and dispose of. Demo structure, with water, with non friable roofing intact then dispose of.

Air Monitoring Firm	
Name:	Asbestos License Number:
Envirologic of New York, Inc.	29383

Laboratory Performing Analysis	
Name:	ELAP Registration Number:
Envirologic	11555

Type of Asbestos Work			
Pipe Related:	Yes	Siding:	No
Clean up:	No	Vessel covering:	No
Caulking/mastic:	No	Spray-on insulation:	No
Roofing/flashing:	Yes	VAT:	No
Demolition:	Yes	Demolition Ref#:	
Other-specify:			

INSPECTION SUMMARY REPORT
New York State Department of Labor Asbestos Control Bureau

CASE NUMBER : 26055122 **PROJECT SITE : 68 Church Rd**
Canajoharie, NY

Waste Transporter

Name: Ciotti NYS DEC or EPA Permit Number: 7A-480 Phone Number: 315-463-4416 Apt./Suite: Address Line 1: 6533 Badgley rd Address Line 2: City Town or Village: East Syracuse Province: State: NY Zip Code: 13057 Country: United States

Landfill

Name: Ontario County Landfill Phone Number: 585-526-4420 Apt./Suite: Address Line 1: 1879 St. Rt. 5 Address Line 2: City Town or Village: Stanley Province: State: NY Zip Code: 14561 Country: United States

Type and Amount of Asbestos Containing Material
--

Friable linear feet:	0	Friable square feet:	4000
Non-friable linear feet:	0	Non-friable square feet:	466864

Fee

Total linear feet: 0.0 Total square feet: 470864.0 Total Fee: 2000.0
--

Project Fee Schedule

If the notification was submitted prior to 4/7/09, the actual project fee is one half of the amount shown on the fee schedule

Linear Feet:	Fee	Square Feet:	Fee
0 - 259 feet:	\$0	0 - 159 feet:	\$0
260 - 429 feet:	\$200	160 - 259 feet:	\$200
430 - 824 feet:	\$400	260 - 499 feet:	\$400
825 - 1649 feet:	\$1000	500 - 999 feet:	\$1000
1650 or more feet:	\$2000	1000 or more feet:	\$2000

Remarks

INSPECTION SUMMARY REPORT
New York State Department of Labor Asbestos Control Bureau
CASE NUMBER : 26055122 **PROJECT SITE : 68 Church Rd**
Canajoharie, NY

7/31/2014 - Inspected By: Louis Carrock

On 7/31/2014, IH Lou Carrock conducted a routine inspection at the former Beechnut Factory in Canajoharie at the request of the Cliff Dorough, the Village of Canajoharie Codes Offier. Mr. Dorough was concerned because he had heard the new contractor was going to start demolishing the East end of the complex and he was not sure if that section of the complex had been cleared of asbestos containing material. I had arraigned to meet Gary Jones and Greg Duck, Investigators for the Workers Compensation Board at the site. Workers Compensation was also conducting an investigation into Infinity Enterprises, the notified abatement contractor. Upon arrival at the complex, I made contact with Infinity owner and supervisor Mark Lindsley and also the owners representative Jeff Wendel. Likewise, the Village of Canajoharie Codes Officer Cliff Dorough, the Village Chief of Police Brian MacFadden and the Mayor of Canajoharie all were in attendance for this inspection.

I asked if they had already picked up the wrapped pipe that was on the ground during my last inspection on 6/25/14. Mr. Lindsley said all of the wrapped pipes had been placed in the lined dumpsters. I asked to see the dumpsters and was escorted by Mr. Lindsley to the waste container area. The first dumpster had a tarp over it and I asked Mr. Lindsley to pull the tarp back to make sure all ACM waste was properly wrapped and/or containerized. I observed that some of the wrapped pipes had large tears and the asbestos material was loose in the lined dumpster. I looked in the second dumpster and again I observed loose ACM debris not wrapped or containerized. I told Mr. Lindsley that the loose ACM in the dumpsters were not in compliance with CR 56 or site specific variance #14-0590. All ACM pipe wrap needed to be either wrapped in 2 layers of plastic. As per 56-8.5(e) the dumpsters MUST be kept free of uncontainerized asbestos waste/debris at ALL times. I informed Mr. Lindsley I would be issuing Infinity Enterprises a citation for a violation of this Section of CR 56.

I was asked if they could start the demolition of the Eastern most section of the complex where abatement of the ACM TSI had been completed. I asked to see the area to confirm no suspect ACM debris remained in the area they wanted to demolish. As we walked through the section of the building slated for immediate demolition I observed several areas where suspect ACM debris littered the ground. Infinity had not conducted any abatement in this area so I could not accuse them of leaving the suspect ACM debris in this area. However, I told Mark Lindsley and the owners representative Jeff Wendell not to start the demolition of the complex until a new asbestos site assessment and subsequent CR 56 compliant clean-up was conducted.

Infinity cited under Section 56-8.5(e); Waste Housekeeping for having the uncontainerized asbestos in their dumpster. An assessment and site specific variance required to properly clean both the dumpster area and the ground in the area where I observed suspect ACM that was slated for immediate demolition.

INSPECTION SUMMARY REPORT
New York State Department of Labor Asbestos Control Bureau

CASE NUMBER : 26055122 **PROJECT SITE :** 68 Church Rd
Canajoharie, NY



7/31/2014 - Uncontainerized asbestos in waste dumpster.